

- Equipment installed in hazardous area shall be certified for Zone 2 Group II A Temp T3 at minimum
- Equipment shall be suitable for offshore marine environment
- Structural design of cabinet shall be suitable for installation on a FPSO
- Cabinet installed indoor shall have front and rear access, minimum depth of 1000mm, 800mm width and 2000mm of height (including base plinth), front plexiglass and honey comb and rear door should be two-honeycomb opening centre.
- Equipment installed outdoor shall be certified IP 66 and indoor equipment room shall be IP 41 at minimum.
- All electrical equipment installed in hazardous areas shall be certified for the area in accordance with IEC Ex
- Supplier should provide an option for future remote operation at Onshore, activities associated with operation, maintenance and engineering that can be performed at the FPSO via the COMPANY (ConocoPhillips) IT Network.
- Contract Award 2019(*); Delivery 2020(*) all units

Project Registration

ConocoPhillips is committed to ensuring Australian Industry full, fair and reasonable opportunity to participate in the Barossa Offshore Project. Expressions of Interest are invited from contractors and suppliers with the relevant capability and capacity to undertake the scope of work.

This is a request for specific expressions of interest. Contractors and suppliers will be considered for prequalification and tender if suitably qualified against this package.

Note that an important part of the project registration process is to register an Expression of Interest at the correct Scope level.

Scope level definition:

Full scope: Able to produce / supply the entire package.

Partial scope: Able to produce / supply one or more of the sub-packages.

All registrations are to be completed via ICN Gateway BarossaOffshore.icn.org.au. Please contact the ICNNT if registration assistance is required. Contact details: (08) 8922 9422 or admin@icnnt.org.au.

Project Website: ConocoPhillips Australia