



## PLUTO LNG TRAIN 2

SR Number: 26221-100-MRA-MWC0-00001

Title: Anti- Foam Metering & Injection System

Scope of Work: Drawings & Data submittal Electronically  
Manufacture and Testing  
Commercial Requirements  
Quality System Description and Requirements

All equipment provided must meet local codes for Western Australia, Project Specifications, as well as any other Australian/local regulation, statutory requirements, and Australian codes and standards as applicable. Each Piece of equipment must be registered with the local regulatory authority.

1 ea. Anti-Foam Metering & Injection system  
Each consisting of: Anti Foam Tank, Anti Foam Mixer, (2) Chemical Metering Pumps, Pump Calibration Cylinder/Column, Control Panel, Valves and Interconnecting Piping

This package will be used to store, mix, and deliver a silicone based anti-foaming chemical to the Acid Gas Removal systems of the Plant.