



PLUTO LNG TRAIN 1: SCARBOROUGH MODIFICATIONS

MR Number: 26457-110-MRA-MEE0-00001

Title: Electric Process Heaters

Scope of Work: Skid mounted electric heaters will be used to heat up hydrocarbon process gas streams and shall be equipped with associated controllers and control panels. The electric heater will be located outdoors and shall be located in an electrically classified area. The control panel will be installed inside the substation which will be considered an electrically non-hazardous area. Electric heater shall have a design pressure of 7500 kPag and design temperature of 250°C and a design duty of approximately 500 kW.

All equipment provided must meet local codes for Western Australia, Project Specifications, as well as any other Australian/local regulations, statutory requirements, and Australian codes and standards as applicable.

Security Level 3 - Bechtel Internal And Selected External Distribution

Confidential © 2022 Bechtel (Western Australia) Pty Ltd.

Electronic documents, once printed, are uncontrolled and may become outdated.

Refer to the Electronic Document Management System for current versions